


#### Best Practices

- 1.) Turn off motors when not in use
- 2.) Size the motors correctly
- 3.) Use energy efficient motors
- 4.) Use cogged V belts or synchronous belt drives
- 5.) Trim impellers or use a VSD instead of using bypass or valves throttling (in cases of excess flow/oversized pumps)
- 6.) Use low head-loss fitting
- 7.) Reduce pipe/duct length and turns
- 8.) Reduce entrance/exit head loss
- 9.) Install variable speed drive (VSD)
- 10.) In intermittent operations, run motor slower and longer



System	Things to Check	Comments
Pumps and Fans	<ul style="list-style-type: none"> <li>• Opportunity with motor sizing</li> <li>• Opportunity with motor efficiency</li> <li>• Opportunity with motor control</li> <li>• Opportunity with scheduling</li> <li>• Opportunity with degraded motors</li> <li>• Opportunity with optimizing pump flow</li> </ul>	<ul style="list-style-type: none"> <li>• Oversized motors consume more energy</li> <li>• Look into resizing the motor or apply variable speed control</li> <li>• Are NEMA premium efficiency motors used?</li> <li>• Are the motors the right type for the application, e.g. totally enclosed vs. partially enclosed?</li> <li>• Is the equipment controlled for flow or pressure? Any throttling?</li> <li>• Is there more flow than required to meet system requirements? → Higher flow requires more energy</li> <li>• Can the fan / blower be turned off or down during low production times?</li> <li>• Can fan/pump be cycled with production throughput?</li> <li>• Are the motors worn out/ eroded? → degraded equipment performance</li> <li>• Are pumps being run dead headed?</li> <li>• Suction problems – inadequate suction head, poor geometry, obstructions</li> <li>• Are there opportunities to reduce head?</li> <li>• Is re-circulation used instead of pump control?</li> </ul>
System	<ul style="list-style-type: none"> <li>• Opportunity with leaks</li> <li>• Are redundant units being run?</li> <li>• Opportunity with optimizing duct/pipe sizing/ flow paths</li> </ul>	<ul style="list-style-type: none"> <li>• Identify and fix air and water leaks</li> <li>• Shut them down</li> <li>• Are there any unneeded flow paths? → More work needed to overcome friction losses</li> <li>• Is there sufficient distance between fan and the first elbow tee? Fans need piping to be 3 x diameter of the fan blade before the first elbow tee to avoid system effect.</li> </ul>