

### Rules of Thumb for Chilled Water Systems

- $\Delta T$  of 10°F = 2.4 gpm/ton;  $\Delta T$  of 12°F = 2 gpm/ton;  $\Delta T$  of 16°F = 1.5 gpm/ton.
- On a centrifugal chiller, if the chilled water temperature is raised by 2°F to 3°F, the system efficiency can increase by 3 - 5%.
- On a centrifugal chiller, if condenser water temperature is decreased by 2°F to 3°F, the system efficiency can increase by 2 - 3%.
- For every 10°F of water temperature drop across the cooling tower, there is an evaporative loss of approximately 1%, equating to 2.5 to 4.0 gpm per 100 tons of capacity.

### Rules of Thumb for HVAC Systems

Ventilation Rate	5 CFM/person	Set points for distribution system	Rebuilt Systems Design	55°F supply air	
Fan Energy	1000-1500 CFM/hp			30°- 40° rise reheat coils	
Chiller Size	300-400 ft <sup>2</sup> /ton		Dual Duct and Multizone design	55° cold deck	
Ton	12,000 BTU/ton			70-105° hot deck – with ODA Reset Schedule	
Chilled Water	2.4 GPM/ton (10 F rise)		VAV	55°F cooling	
Condenser Water	3 GPM/ton (10 F rise)			10% box leakage flow	
People Load	450 BTU/person/hr			40-50% minimum fan volume	
Infiltration	0.5-1.5 ACH without building pressurization		<b><u>Typical Chiller Efficiencies in kW/ton</u></b>		
Heat Transmission Through Envelope	Overall Building – 0.15 to 0.5 BTU/ft <sup>2</sup> /F See ASHRAE Handbook of Fundamentals for accurate heat loads by envelope types	Chiller Type	ASHRAE Standard 90.1 Minimum	Good	Best
		Air - Cooled	1.26	1.21	1.13
		Water - Cooled	0.72	0.65	0.45

### Quick Calculations and Conversions

$$EER = COP \times 3.412$$

$$kW/Ton = 12/EER$$

$$kW/Ton = 12/(COP \times 3.412)$$

$$1 \text{ psi} = 2.31 \text{ ft w.g.}$$

$$1 \text{ l/s} = 15.85 \text{ GPM}$$

$$1 \text{ l/s} = 2.12 \text{ CFM}$$

$$Q(\text{Btu/hr}) = 500 \times \text{GPM} \times \Delta T \text{ (Chilled Water)}$$

$$Q(\text{Btu/hr}) = 1.08 \times \text{CFM} \times \Delta T \text{ (Air Sensible Heat)}$$

$$Q(\text{Btu/hr}) = 0.69 \times \text{CFM} \times \Delta \left(\frac{\text{gr}}{\text{lb}}\right) \text{ (Air Latent Heat)}$$

$$Q(\text{Btu/hr}) = 4.5 \times \text{CFM} \times \Delta h \text{ (Air Total Heat)}$$

$$\text{Ton (Cooling Tower)} = 15 \text{ MBH} = 15,000 \text{ BTU/h}$$

